



Government of West Bengal
Office of the Deputy Chief Medical Officer of Health -II,
N/SL,46/1 Rajarammohan Roy Road(Bye lane)
East Vivekanandapally,P.O. Rabindra Sarani
Siliguri 734006
Darjeeling


Memo No FS/SLG/ 68/26

18th May, 2026

To,
The Principal,
Hardy Ramanujan Public School,
Patharghata,Helapakrijote, New Chumta,
Salbari,Siliguri

Sanitary Certificate.

With reference to your application dated 12th May 2026 and also subsequent inspection of the appropriate authority, the undersigned would like to certify that the sanitation of the school premises and its surroundings relating to public health and including provision of clean drinking water and waste disposal has been found to be hygienic as per the departmental standards.


DO Food Safety, Darjeeling
&
SFSIO, WB


Memo No FS/SLG/ 68/26


18th May 2026

Copy forwarded for information to:

1. The Chief Medical Officer of Health.Darjeeling
2. The Asstt C M O H, Siliguri
3. The BMOH,Matigara.
4. Office copy

DO Food Safety, Darjeeling
&
SFSIO, WB

Hardy Ramanujan Public School

Manager

Hardy Ramanujan Public School

Principal

NORTH BENGAL CHEMICAL TESTING AND ANALYSIS LAB (NBCTAL-MAY-2026 MICRO-DIVISION)

Registered Under Govt. of West Bengal, DIC Entrepreneur's Memorandum No.: 190012110563 dt. 09/10/2009.
Registered Under Govt. of India, MSME Udyog Aadhaar Registration UAM No.: WB06D0003024 dt. 12/02/2020.
Sample deposit & Report Collection Office Cum Lab: Maa Kalyani Kall Bari, Gadadhar Sarani
Rabindra nagar, P. O Rabindra Sarani, Siliguri, Pin-734006, Dist-Darjeeling, State-West Bengal, India.
Email. nbctslg09@gmail.com

Certificate for Water analysis

Name and address of client:

M/S. HARDY RAMANUJAN PUBLIC SCHOOL,
PATHARGHATA, HELAPAKRIJOTE, P.O. NEW CHUMTA
SAURANI, DIST.DARJEELING, PIN-734009.

Analysis Report Number

NBCTAL /05/2026/19

RESULTS OF ANALYSIS

Sample Received on	Analysis Duration	Sample Description & Work /Service Order No. of client's, Work Order Dated.	Quantity of Sample	Sample Submitted by
16/05/2026	16/05/2026 to 19/05/2026	i) Source & Type of sample—Water Filter ii) Collection Site— Patharghata iii) Date & Time of Collection —16/05/2026 & 05.00 PM iv) Purpose of use— Drinking. v) Number of samples to be Tested—01 Work Order No. WATER TEST, Dated—16/05/2026.	2 x 500ml (approx.)	Drawn by Party (Sample will be destroyed by us after issuance of this certificate).

Table 1- Physical Parameters Test:

Sl.No.	Parameter	Acceptable Limit	Permissible Limit	Method IS 3025 Part	Result Obtained
1.	Colour (Hazen)	5	15	Part 4	1
2.	Odour	Agreeable	—	Part 5 (Annex C)	Agreeable
3.	Taste	Agreeable	—	Part 5	Agreeable
4.	Turbidity (NTU)	1	5	Part 10	0.32
5.	pH	6.5–8.5	No relaxation	Part 11	7.0
6.	Electrical Conductivity ($\mu\text{S}/\text{cm}$)	< 750	< 3000	Part 14	142
7.	TDS (mg/L)	500	2000	Part 16	86

Table 2- General Chemical Parameters Test:

Sl.No.	Parameter	Acceptable Limit	Permissible Limit	Method IS 3025 Part	Result Obtained
8.	Total Hardness (mg/L as CaCO_3)	200	600	Part 21	45
9.	Total Alkalinity (mg/L as CaCO_3)	200	600	Part 23	28
10.	Free Residual Chlorine(mg/L)	0.2	1.0	Part 26	0.2
11.	Dissolved Oxygen (mg/L)	26	—	Part 38	6.6

Table 3- Metals Parameters Test:

Sl.No.	Parameter	Acceptable Limit	Permissible Limit	Method IS 3025 Part	Result Obtained
12.	Iron (mg/L as Fe)	0.3	No relaxation	Part 53	0.05
13.	Manganese (mg/L as Mn)	0.1	0.3	Part 59	0.02

Table 4- Bacteriological Test:

Sl.No.	Parameter	Acceptable Limit	Permissible Limit	Method IS 3025 Part	Result Obtained
14.	Total Coliform (MPN/100 mL)	Absent	—	Part 44	Absent
15.	E. coli (MPN/100 mL)	Absent	—	Part 44	Absent

IMPRESSION / REMARK: The above tested parameters were analyzed as per IS 3025 methods. Based on the parameters tested, the results are within the acceptable limits of IS 10500:2012. Bacteriological examination indicates Bacteria absent at the time of testing.

Date of Issue: 2005/2026

For N.B.C.T.A.L
S. K. Sengupta
(Authorized Signatory)

NOTE:

- The results given above are related to the tested sample, as received & parameters as mentioned in Work Order by the customer for the above tests only.
- In case of lack of correlation due to technical/typing error, laboratory should be informed immediately for rectification/review/resembling and retesting etc.
- This test report will not be generated again, either wholly or in part, without permission of the Laboratory.
- Contents of this report are meant for your guidance and should not be used for advertisements, evidence or litigation. NBCTL is not an NABL lab.
- Responsibility of the Laboratory is limited to the invoiced amount only. Any type of consultancy on plant/project set up is not provided by NBCTAL.

REPORT ENDS

Hardy Ramanujan Public School

[Signature]

Manager

Hardy Ramanujan Public School

[Signature]

Principal



Office of the

PATHARGHATA GRAM PANCHAYAT

Venchijote, P.O.- New Chumta, Dist.- Darjeeling, 734009

Email : patharghatagpoff@gmail.com

Memo No.- 689/PGP/2026

Date: 21/09/2026

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

This is to certify that Hardy Ramanujan Public School, situated at Helapakuri, P.O New Chumta, P.S- Matigara, Dist.- Darjeeling, Pin-734009, WB under Patharghata Gram Panchayat has been inspected regarding its basic amenities and sanitation infrastructure.

Based on the local inspection and available facilities:

1. The school premises are maintained in a clean, hygienic, and sanitary condition.
2. The school provides functional, separate toilets for boys and girls with adequate running water.
3. Safe drinking water facilities (via [RO Unit / Tap Water / Deep Tube Well]) are installed and accessible to students and staff.

This certificate is valid for a period of One Year from the date of issue.

This certificate is issued upon the request of the school authority for local record purposes.

Signature with Seal: _____

Pradhan

Patharghata Gram Panchayat

Name: MD SAHID

Venchijote, New Chamta, Darjeeling

Designation: Pradhan, Patharghata Gram Panchayat

To:

Hardy Ramanujan Public School
Helapakuri, P.O.- New Chumta
P.S.- Matigara, Dist.- Darjeeling
Pin- 734009, WB

Hardy Ramanujan Public School

Manager

Hardy Ramanujan Public School

Principal