



GOVERNMENT OF WEST BENGAL,
DIRECTORATE OF PUBLIC HEALTH ENGINEERING,
OFFICE OF THE EXECUTIVE ENGINEER,
SILIGURI WATER SUPPLY DIVISION,
DISTRICT LABORATORY AT FULBARI,
SILIGURI

PHYSICAL AND CHEMICAL TEST REPORTS :


Date Of Collection	30.11.2022
Date Of Analysis	30.11.2022
Date Of Reporting	30.11.2022


SL. NO.	Parameters	Acceptable Limit	Cause of Rejection	RESULT	
				Place	Patharghata
				Source	Filter House
				Sender	Principal, Hardly Ramanujan Public School
1.	Turbidity (NTU)	1	5		0.32
2.	pH	7.0 to 8.5	<6.5 or >9.2		6.89
3.	Colour(Hz)	5	25		0
4.	Iron (mg/l)	0.1	1.0		0
5.	Res. Chlorine (mg/l)	0.2	>1.0		0
6.	Fluoride (mg/l)	1.0	1.5		0
7.	Total Hardness(mg/l)	300	600		10
8.	Total Alkalinity(mg/l)	200	600		16
9.	Chloride (mg/l)	200	600		29.15
10.	Nitrate (mg/l)	45	45		4.25
11.	Copper (mg/l)	0.05	0.5		0


*The tests done with the Sample as deposited by the Party.

Physical & Chemical Test Charge Rs. 900.00/-

Received Vide Money receipt No. 1902 Dated : 11/11/2022

✓ 
Chemist/Bacteriologist,
District Laboratory,
Fulbari, W.T.P.


Junior Engineer,
Siliguri Water Supply Division,
P.H. Engineering Dte.



Assistant Engineer-1,
Siliguri Water Supply Division,
P.H. Engineering Dte.

Memo No. 1979 /SWSD /SD: Dated, Siliguri, the 12.12. 2022

Copy forwarded for information and necessary action to:-

1. Principal, Hardly Ramanujan Public School.
2. Office Copy.

Report No: Chem/2022/Nov-49


Executive Engineer,
Siliguri Water Supply Division,
P.H. Engineering Dte.

Hardy Ramanujan Public School

Manager

Hardy Ramanujan Public School
Kabita Basad
Principal



GOVERNMENT OF WEST BENGAL,
DIRECTORATE OF PUBLIC HEALTH ENGINEERING,
OFFICE OF THE EXECUTIVE ENGINEER,
SILIGURI WATER SUPPLY DIVISION,
DISTRICT LABORATORY AT FULBARI,
SILIGURI

BACTERIOLOGICAL ANALYSIS:


Date Of Collection	30.11.2022
Time Of Collection	11.20 AM
Date Of Analysis	30.11.2022 TO 01.12.2022
Date Of Reporting	01.12.2022


Sl No.	Bacteriological Parameters	Acceptable Limit	RESULT	
			Place	Patharghata
			Source	Filter House
			Sender	Principal, Hardly Ramanujan Public School
1.	Total Coliform Present/Absent MPN (per 100ml)	Absent		ABSENT
2.	Faecal Coliform Present/Absent MPN (per 100ml)	Absent		ABSENT
3.	WATER BACTERIOLOGICALLY SAFE/UNSAFE	--		SAFE


*The tests done with the Sample as deposited by the Party.

Bacteriological Test Charge Rs. 500.00/-

Received Vide Money receipt No. 1902 Dated: 11/11/2022


Chemist/Bacteriologist,
District Laboratory,
Fulbari, W.T.P.


Junior Engineer,
Siliguri Water Supply Division,
P.H. Engineering Dte.



Assistant Engineer-1,
Siliguri Water Supply Division,
P.H. Engineering Dte.


Memo No. 1980/SWSD/SD Dated, Siliguri, the 12-12-2022

Copy forwarded for information and necessary action to:-

1. The Principal, Hardly Ramanujan Public School.
2. Office Copy

Report No: Bact/2022/Nov- 43


Executive Engineer,
Siliguri Water Supply Division,
P.H. Engineering Dte.

Hardy Ramanujan Public School

Manager

Hardy Ramanujan Public School
Kabilabasad
Principal